

## Emergency Load Curtailment Program (ELCP)

All ELCP communications from TVA will come to System Operations (SysOps) by automatic notification.

### **Step 10—In House Load Reduction.**

- SysOps emails notification to Office Managers and CC Senior Directors & Corporate Team.
- Office Managers, except for the Shelbyville District Office Manager, turn off hallway lights and adjust the thermostats.
  - Winter Temperature 60°
  - Summer Temperature 78°
- Shelbyville Office Manager turn off hallway lights and contact Field Services Manager to adjust thermostats for Shelbyville Office and Annex.
- Office Managers contact their satellite office to turn off lights & adjust thermostats.

### **Step 20—Members to Reduce**

- No public communication to reduce usage will be issued by DREMC.

### **Step 30—Voltage Reduction**

- SysOps and Operating Engineer reduce via SCADA within the defined parameters of ANSI Standards.

### **Step 40—Large Members to Reduce**

- Anyone on an IP rate will be notified by the Business Programs Specialist.

### **Step 50—Interruption of Load**

- Senior Director over SysOps will communicate with the System Operators.

### **Step 60—TVA Tripping of Firm Load**

- Senior Director over SysOps will communicate with the System Operators.